

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7271-1429:118 Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: Secutron, Div. of Digital Security Controls LTD, 3301 Langstaff Rd, Ontario Canada L4k 4L2
Contact: Paul Mattern (978) 731-8542 FAX (978) 731-8881

DESIGN: Model MRI-1251B ionization smoke detector. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as an ionization smoke detector when used in conjunction with System Sensor's listed Model B501, B501BH and B210LP bases (CSFM Listing No. 7300-1209:128) and separately listed compatible fire alarm control units. Suitable for open area protection at air velocities up to 1200 fpm. Refer to listee's Installation Instruction Manual for details.

XLF: 7271-1209:158

06-19-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 16, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager